

## REPORT DOCUMENTATION PAGE

AFRL-SR-AR-TR-03-

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestion Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork...

0182

ng  
on

## 1. AGENCY USE ONLY (Leave blank)

## 2. REPORT DATE

13 May 2003

## 3. REPORT TYPE AND DATES COVERED

FINAL REPORT 15 MAY 01 TO 14 NOV 02

## 4. TITLE AND SUBTITLE

ACQUISITION OF AN ALL-SOLID STATE FEMTOSECOND LASER SYSTEM

## 5. FUNDING NUMBERS

F49620-01-1-0319

## 6. AUTHOR(S)

Professor V.A. Apkarian

2303/EX

61102F

## 7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES)

University of California, Irvine  
Department of Chemistry  
317B Rowland Hall  
Irvine, CA 92697-2025

8. PERFORMING ORGANIZATION  
REPORT NUMBER

## 9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)

AFOSR/NL  
4015 Wilson Blvd., Suite 713  
Arlington, VA 22203-1954

10. SPONSORING/MONITORING  
AGENCY REPORT NUMBER

## 11. SUPPLEMENTARY NOTES

20030602 132

## 12a. DISTRIBUTION AVAILABILITY STATEMENT

Approve for Public Release: Distribution Unlimited

## 12b. DISTRIBUTION CODE

## 13. ABSTRACT (Maximum 200 words)

We have successfully constructed a rather unique femtoscenc laser system, which has already been quite productive. The system was designed around a commercial pump source, the Clark MXR-2001 system, which is a diode-pumped, additive chirp mode locked fiber laser, regeneratively amplified to produce 775 nm pulses of ~160 fs, 800 mW, at 1KHz. The output of the pump laser is split successively with 50% beam splitters, to use ~200 mW beams to pump two home-built Non-collinear Optical Parametric Amplifiers (NOPA). The latter have innovative details, to generate final outputs of 10 uJ/pulse, at 1 KHz, with pulsewidths of 10-30 fs, in the entire visible spectrum. The system enables nonlinear multicolor, multi-beam measurements, of quantum coherences, with experimental time resolution of 14 fs, in notoriously difficult measurements of 4-wave and 6-wave mixing in condensed media. The design of the NOPA is illustrated in Fig.1. The pump entering the NOPA is split between two arms, 4% is used to generate white light in a 200um sapphire disk, while the rest is used to double in a BBO x-tal, then to pump the NOPA x-tal to generate super radiance. The white light is volume matched with the superradiance on a 14' incline, and the time-spectral overlap of the chirped white light is amplified. The single delay line of TSI in the figure is sufficient to tune the color of the output. The bandwidth of the output is controlled by the chirp in the white light. Typiccally, bandwidths that can sustain 10 fs operation can be obtained by adjusting the white light optics. While ultrashort pulses are the aim of our setup, in many measurements longer pulses are desired. This can be managed by inserting a dispersion element in the white light arm, a water cell or an SF10 blank of variable length is used to this end.

## 14. SUBJECT TERMS

## 15. NUMBER OF PAGES

## 16. PRICE CODE

17. SECURITY CLASSIFICATION  
OF REPORT

UNCLAS

18. SECURITY CLASSIFICATION  
OF THIS PAGE

UNCLAS

19. SECURITY CLASSIFICATION  
OF ABSTRACT

UNCLAS

## 20. LIMITATION OF ABSTRACT

**FINAL REPORT**  
**AFOSR (F49620-01-1-0319)**  
**ACQUISITION OF AN ALL-SOLID STATE FEMTOSECOND**  
**LASER SYSTEM**

We have successfully constructed a rather unique femtosecond laser system, which has already been quite productive.<sup>1,2</sup> The system was designed around a commercial pump source, the Clark MXR-2001 system, which is a diode-pumped, additive chirp mode locked fiber laser, regeneratively amplified to produce 775 nm pulses of ~160 fs, 800 mW, at 1KHz. The output of the pump laser is split successively with 50% beam splitters, to use ~200 mW beams to pump two home-built Non-collinear Optical Parametric Amplifiers (NOPA). The latter have innovative details, to generate final outputs of 10  $\mu$ J/pulse, at 1 KHz, with pulsewidths of 10-30 fs, in the entire visible spectrum. The system enables nonlinear multicolor, multi-beam measurements, of quantum coherences, with experimental time resolution of 14 fs, in notoriously difficult measurements of 4-wave and 6-wave mixing in condensed media.

The design of the NOPA is illustrated in Fig. 1. The pump entering the NOPA is split between two arms, 4% is used to generate white light in a 200 $\mu$ m sapphire disk, while the rest is used to double in a BBO x-tal, then to pump the NOPA x-tal to generate super radiance. The white light is volume matched with the superradiance on a 14° incline, and the time-spectral overlap of the chirped white light is amplified. The single delay line of TS1 in the figure is sufficient to tune the color of the output. The bandwidth of the output is controlled by the chirp in the white light. Typically, bandwidths that can sustain 10 fs operation can be obtained by adjusting the white light optics. While ultrashort pulses are the aim of our setup, in many measurements longer pulses are desired. This can be managed by inserting a dispersion element in the white light arm, a water cell or an SF10 blank of variable length is used to this end (not shown in the figure).


We are quite proud of the system, which was built entirely by graduate students in record time, and which has already produced impressive data. As such, details of the design and performance will be published in a manuscript that is nearly complete.<sup>3</sup>

---

<sup>1</sup> M. Karavitis, D. Segale, Z. Bihary, M. Pettersson, and V. A. Apkarian, Low Temp. Physics (in press) "Time resolved CARS measurements of vibrational decoherence"

<sup>2</sup> Z. Bihary, M. Karavitis and V. A. Apkarian, J. Phys. Chem. (submitted, 2002) "Onset of decoherence: Six-wave mixing measurements of vibrational decoherence on the excited electronic state "

<sup>3</sup> M. Karavitis and V. A. Apkarian (in prep), "Long-lived, coupled impurity-cage vibrational coherences"



Distance from 4% BS to BBO2: 93cm

BBO1: 5 x 5 x 1 mm, p-Coated, 30 degree cut

BBO2: 5 x 5 x 2 mm, uncoated, 28 degree cut

DM1 = DM2: Dichroic Mirror (HR 400, HT 800)